

**OFFICE OF THE SUPERINTENDING ENGINEER, RWS&S DIVISION
BHANJANAGAR-761126.**

Letter No. 1436 / Date. 15/04/23

To,

The Head Mistress,
ST.ANN'S English Medium School, Bhanjanagar

Sub- Submission testing report of water samples.


Ref. No - Letter No.- Dt.-13.04.2023

Sir,

The testing report of water samples of (1) one nos. of ST.ANN'S English Medium School, Badakodanda Bhanjanagar, Ganjam. Chemical & Bacteriological test report is submitted herewith for your kind information and necessary action.

Encl:- Test Report Enclosed.

Yours Faithfully


Superintending Engineer
RWS&S Division, Bhanjanagar
15/04/2023

DISTRICT WATER TESTING LABORATORY ,RWS&S DIVISION BHANJANAGAR

WATER ANALYSIS REPORT

Sample Particulars			Details of sampling		
ST.ANN,S ENGLISH MEDIUM SCHOOL			Type of Source -	BOREWELL	
			Date of Testing-	15.04.2023	
			Location -	ST.ANN,S ENGLISH MEDIUM SCHOOL CAMPUS,BADAKODANDA,BNJ	
Sl. No.	Test Parameters	Units	Results	Acceptable Limit	Permissible Limit
1	PH	pH unit	7.00	6.5-8.5	No relaxation
2	Elect.Conductivity	mho/cm	368.0		1000
3	TDS	Mg/L	239	500	2000
4	Chloride	Mg/L	30	250	1000
5	Hardness	Mg/L	110	200	600
6	Alkalinity	Mg/L	124	200	600
7	Fluoride	Mg/L	0.46	1.0	1.5
8	Iron	Mg/L	0.59	1.0	1.0
9	Turbidity	NTU	0.87	1.0	5.0
10	Total Coliform	MPN Method	0.00	0.00	0.00

M.M.Pandey
 Laboratory Chemist
 RWS&S Division Bhanjanagar
 15/04/23

PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE

It is Certified that an inspection team headed by Sri Saroj Kumar Kar, Superintending Engineer from RWS&S Division Bhanjanagar inspected the ST.ANN'S English Medium School, Sanapathara, Daha Road, Po-Badakodanda, Bhanjanagar, Ganjam (Odisha) on dt-15.04.2023 and found the ST.ANN'S English Medium School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms described by the central/state/U.T.Govt.

The above valid for a period of- 1 year (15.04.2024)

Signature with seal:

Name

Designation

: Sri Saroj Kumar Kar

: Superintending Engineer
RWS&S Division Bhanjanagar


Memo No-

1436

Dt-

15/04/23

Copy forwarded to the Head Mistress the ST.ANN'S English Medium School, Sanapathara, Daha Road, Po-Badakodanda Bhanjanagar, Ganjam, Odisha for information and necessary action.


15/04/2023
Superintending Engineer
RWS&S Division Bhanjanagar