

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

349

Dated.

30-04-2024

It is Certified that an inspection team headed by Sri Nihar Ranjan Swain, Asst.Executive Engineer, (Name of Officers with designation) from Rural Water Supply & Sanitation (Name of Department / Office) inspected ST.ANN.S English Medium School ,Bhanjanagar (Name & Address of the School) on 26.04.2024 (date of Inspection) and found that ST.ANN.S English Medium School, Bhanjanagar (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the School Building & the campus as per norms prescribed by the Central / State / U.T.Govt.

The above is valid for a period of One Year


Asst. Executive Engineer

Signature with Seal: ...RWSS Sub-Division.....

Name

Bhanjanagar
: Nihar Ranjan Swain

Designation

: Asst.Executive Engineer

Name & Address of

The Office / Department: Rural water Supply &
Sanitation

To

The Head Mistress,

St.Ann.s English Medium School, Bhanjanagar.

(Name & Address of the Institution)

DISTRICT WATER TESTING LABORATORY ,RWS&S DIVISION BHANJANAGAR

WATER ANALYSIS REPORT

Sample Particulars			Details of sampling		
BLOCK-BHANJANAGAR			Type of Source -	BOREWELL	
			Date of Testing-	26.04.2024	
			Location -	ST.ANN.S English Medium School	
Sl. No.	Test Parameters	Units	Results	Acceptable Limit	Permissible Limit
1	PH	pH unit	7.10	6.5-8.5	No relaxation
2	Elect.Conductivity	mho/cm	374.0		1000
3	TDS	Mg/L	243.1	500	2000
4	Chloride	Mg/L	46	250	1000
5	Hardness	Mg/L	142	200	600
6	Alkalinity	Mg/L	110	200	600
7	Fluoride	Mg/L	0.12	1.0	1.5
8	Iron	Mg/L	0.08	1.0	1.0
9	Turbidity	NTU	0.51	1.0	5.0
10	Total Coliform	MPN METHOD	0.00	0.00	0.00

N. U. Madhavi
 26/04/24
 Laboratory Chemist
 RWS&S Division, Bhanjanagar
 RWS&S Division, Bhanjanagar