

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 125

Dated 2/5/2022

It is certified that an inspection team headed by Er. Shubhajit Lenka, Asst. Executive Engineer(Name of Officers with designation) from Rural Water Supply & Sanitation(Name of Department/ Office) inspected the ST. ANN'S English Medium School, Bhanjanagar(Name & Address of the school) on 06.05.2022 (date of inspection) and found that the ST. ANN'S English Medium School, Bhanjanagar (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining sanitation condition in the school building & the campus as per norms prescribed : 6/12/20
State/ U.T. Govt.The above is valid for a period of One Year

Signature with Seal Assistant Executive Engineer

Name

RWS & S Sub-Division
Er. Shubhajit Lenka

Designation

Asst. Executive EngineerName & Address of the Office / Department Rural
Water supply & Sanitation
Bhanjanagar.

To

Head Mistress,ST. ANN'S English Med. School, Bhanjanagar.


(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

DISTRICT WATER TESTING LABORATORY, RWS&S DIVISION BHANJANAGAR

WATER ANALYSIS REPORT

Sample Particulars			Details of sampling		
BLOCK-BHANJANAGAR			Type of Source -	BOREWELL	
			Date of Testing-	06.05.2026	
			Location -	ST.ANN.S ENGLISH MEDIUM SCHOOL	
Sl. No.	Test Parameters	Units	Results	Acceptable Limit	Permissible Limit
1	PH	pH unit	7.10	6.5-8.5	No Relaxation
2	Elect.Conductivity	mho/cm	372.0		1000
3	TDS	Mg/L	241.8	500	2000
4	Chloride	Mg/L	60	250	1000
5	Hardness	Mg/L	144	200	600
6	Alkalinity	Mg/L	112	200	600
7	Fluoride	Mg/L	0.22	1.0	1.5
8	Iron	Mg/L	0.13	1.0	No Relaxation
9	Turbidity	NTU	0.30	1.0	5.0
10	Total Coliform	MPN METHOD	0.00	0.00	0.00


 06/05/26
 Laboratory Chemist
 RWS&S Division Bhanjanagar
 RWS&S Division Bhanjanagar